



Water Service Recommended Specifications
Waiver And Release Of Liability

Rimersburg Borough

The Rimersburg Borough Municipal Authority (RBMA) strongly recommends that all water service lines be installed with a minimum depth of cover of forty two inches (42”) to prevent freezing during winter months. The RBMA also recommends that all water service lines are at a minimum 3/4” diameter polyethylene tubing (C.T.S. 200 psi), buried under detectable tracer wire, and installed within stone bedding according to specifications on RBMA standard details. The Typical Detail of Drawing No. 2 - Connection Detail with Meter Outside of House provided to all customers at the time of connection shows the installation of these specifications as part of the water service detail.

The Authority has determined that there may be situations where the above recommendations may be difficult to install with reasonable efforts or may not be desired, for any reason, by the property owner; and the Authority has determined that it will not require the installation of the water service to the building according to these specifications, so long as the owner executes this Waiver and Release of Liability.

Check Applicable Waiver:

- _____ Depth of cover less than 42”
- _____ Use of water line other than minimum 3/4” polyethylene (C.T.S. 200 psi)
- _____ Absence of bedding (full-length of waterline cased with Schedule 40 PVC twice the diameter of waterline)
- _____ Connection to existing waterline of unknown specifications

NOW THEREFORE, in consideration of the mutual covenants herein contained, the property owner(s) hereby agree as follows:

1. That the aforesaid recitals are incorporated herein by reference. The property owners are assuming full responsibility for any harm or injury caused by or attributable to, in whole or in part, the lack of recommended specifications on the water service line.
2. That the property owner(s) for themselves, their successors, assigns, personal representatives and heirs do hereby release the RBMA, its officers, officials, agents, servants, employees, and contractors from any and all damages, injuries, including death, as well as any claims by third parties, and further agree to indemnify and hold harmless the RBMA, its officers, officials, agents, servants, employees and contractors of and from any liability including attorney fees and expenses, which may arise from the non-installation of recommended specifications.
3. The property subject to this Waiver is identified as _____
_____, Rimersburg, Pennsylvania _____.

IN WITNESS WHEREOF, and intending to bound hereby, the parties hereto have set their hands and seals the day and year first below written, representing that they are the sole owners of the property or are otherwise authorized to sign this waiver.

(cont. reverse)



Water Service Recommended Specifications
Waiver And Release Of Liability

Rimersburg Borough

Date: _____

Property Owner(s)

(seal)

Witness

Print Name: _____

(seal)

Witness

Print Name: _____